

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 5278-0328:0506 Page 1 of 1

CATEGORY: 5278 -- CARBON MONOXIDE DETECTORS

LISTEE: Potter Electric Signal Co1609 Park 370 Place, Hazelwood, MO 63042 United States
Contact: Michael Mclsaac (314) 628-2218 Fax (314) 595-6999
Email: michaelm@pottersignal.com

DESIGN: Model PAD100-CD carbon monoxide detector head. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 24 Vdc

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes, NFPA 720, and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, UL labeling, electrical rating, and required WARNINGS label.

APPROVAL: Listed as a carbon monoxide head for use with listee's detector base Models PAD100-4DB, PAD100-6DB, PAD100-RB, PAD100-SB (CSFM#7300-0328:502) and Model PAD100-IB (CSFM#7300-0328:501).

NOTE: Carbon Monoxide alarms are not intended/suitable for fire and smoke detection.

06-21-2017 dcc



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG**, Program Coordinator
Fire Engineering Division