

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7272-0328:0507 Page 1 of 1

**CATEGORY:** 7272 -- SMOKE DETECTOR-SYSTEM TYPE-PHOTOELECTRIC

**LISTEE:** Potter Electric Signal Co1609 Park 370 Place, Hazelwood, MO 63042 United States  
Contact: Bill Witherspoon (314) 595-6731 Fax (314) 595-6999  
Email: billw@pottersignal.com

**DESIGN:** Models CPS-24 and CPS-24N photoelectric smoke detector. Detectors are for use with separately listed Hochiki bases. Refer to listee's data sheet for detailed product description and operational considerations

**RATING:** 24 Vdc

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, rating and UL label.

**APPROVAL:** Listed as photoelectric smoke detectors for use with separately listed fire alarm control units and Hochiki bases. Refer to listee's Installation Instruction Manual for details.

**XLf:** 7272-0410:0504

08-30-17 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2020**

*Listing Expires* **June 30, 2021**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**  
*Fire Engineering Division*