



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE
PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

| | |
|----------------------------|--|
| LISTING No.: | 7272-0328:0507 |
| PARENT LISTING No.: | 7272-0410:0504 |
| CATEGORY: | 7272 - SMOKE DETECTOR-SYSTEM TYPE-PHOTOELECTRIC |
| LISTEE: | Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Lakomiak, Neil 314-816-8679 Email: neill@pottersignal.com |
| DESIGN: | Models CPS-24 and CPS-24N photoelectric smoke detector. Detectors are for use with separately listed Hochiki bases. Refer to listee's data sheet for detailed product description and operational considerations |
| RATING: | 24 Vdc |
| INSTALLATION: | In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction. |
| MARKING: | Listee's name, model number, rating and UL label. |
| APPROVAL: | Listed as photoelectric smoke detectors for use with separately listed fire alarm control units and Hochiki bases. Refer to listee's Installation Instruction Manual for details. |
| NOTES: | |

08-30-17 gt



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 06/19/2025

Listing Expires: 06/30/2026

Authorized By: **Michael Huang** , Program Coordinator
Fire Engineering & Investigations Division