



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7135-0328:0508
PARENT LISTING No.:	7135-0569:0148
CATEGORY:	7135 - AUDIBLE DEVICES
LISTEE:	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Lakomiak, Neil 314-816-8679 Email: neill@pottersignal.com
DESIGN:	Models LFHS-15, LFHS-110 and LFHS-177 low frequency horn/strobes. Horn/strobes models may be followed by -W or -R (white or red). Refer to listee's data sheet for additional detailed product description and operational considerations.
RATING:	16-33 Vdc/VFWR Model LFHS-15 15 candela fixed Model LFHS-110 110 candela fixed Model LFHS-177 177 candela fixed
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, electrical rating, and UL label.
APPROVAL:	Listed low frequency horn/strobes when used with a separately listed electrically compatible fire alarm control unit. Horn/strobe models for wall mount only. All models are for indoor use only. These units can generate a low frequency alarm signal for sleeping areas in accordance with NFPA 72. Refer to listee's Installation Instructions Manual for details.
NOTES:	

08-30-17 gt



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 07/26/2024

Listing Expires: 06/30/2025

Authorized By: **David Castillo** , Program Coordinator
Fire Engineering & Investigations Division