



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	7135-0328:0510
<b>CATEGORY:</b>	7135 - AUDIBLE DEVICES
<b>LISTEE:</b>	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Lakomiak, Neil 13148661542 Email: neill@pottersignal.com
<b>DESIGN:</b>	Potter Model MTR-120MH (red) and MTW-120MH (white) audible signal appliance. Intended for installation in a suitable single-gang electrical box, temporal 3 code, indoor use only. Refer to listee's data sheet for additional detailed product description and operational considerations.
<b>RATING:</b>	120 VAC  84 dba at 10'
<b>INSTALLATION:</b>	In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
<b>MARKING:</b>	Listee's name, model number, electrical ratings and UL label.
<b>APPROVAL:</b>	Listed as an audible signal appliance for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.
<b>NOTES:</b>	



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 05/03/2024**

**Listing Expires: 06/30/2025**

Authorized By: **David Castillo**, Program Coordinator  
Fire Engineering & Investigations Division