



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7165-0328:0511
CATEGORY:	7165 - FIRE ALARM CONTROL UNIT (COMMERCIAL)
LISTEE:	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Lakomiak, Neil 13148661542 Email: neill@pottersignal.com
DESIGN:	<p>Potter Model PFC - 4064 fire alarm control panel, Model CA-4064 Expander, Model IDC Expander. Automatic, Manual, waterflow and sprinkler supervisory type device and local, auxiliary, remote station (PPU), proprietary (PPU) and central station (PPU) services.</p> <p>System components:</p> <p>PFC - 4064 Mainboard panel assembly</p> <p>CA - 4064 Class A expander card</p> <p>RA - 6500, RA - 6500R, RA - 6500F LCD remote annunciator</p> <p>UD - 1000 DACT</p> <p>PSN - 1000 Power supply expander</p> <p>IDC - 6 Initiating device expander card</p> <p>LED - 16/16F LED Annunciator</p> <p>DRV - 50 LED driver</p> <p>RLY - 5 Relay expander card</p> <p>FCB - 1000Fiber interface bridge</p> <p>SPG - 1000 Serial/Parallel printer card</p> <p>MC - 1000 Multi-connector module</p> <p>3005013 EOLR</p> <p>3005012 EOLR Diode</p> <p>Refer to listee's Installation Instruction Manual for details.</p>



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

RATING:	Primary Operating Supply: 120/240 VAC 2.5A Secondary Operating Supply 27.3 VDC 1.0 A
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model designation, rating and UL label.
APPROVAL:	Listed as fire alarm control units when use with separately listed electrically and functionally compatible initiating and indicating devices. Refer to listee's Installation Instruction Manual for details.
NOTES:	

03-12-2018 dcc



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 05/03/2024

Listing Expires: 06/30/2025

Authorized By: **David Castillo**, Program Coordinator
Fire Engineering & Investigations Division