CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No.:	7165-0328:0511
CATEGORY:	7165 - FIRE ALARM CONTROL UNIT (COMMERCIAL)
LISTEE:	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Decker, Tim (314) 595-6748 Email: timd@pottersignal.com
DESIGN:	Potter Model PFC - 4064 fire alarm control panel, Model CA-4064 Expander, Model IDC Expander. Automatic, Manual, waterflow and sprinkler supervisory type device and local, auxiliary, remote station (PPU), proprietary (PPU) and central station (PPU) services. System components: PFC - 4064 Mainboard panel assembly CA - 4064 Class A expander card RA - 6500, RA - 6500R, RA - 6500F LCD remote annunciator UD - 1000 DACT PSN - 1000 Power supply expander IDC - 6 Initiating device expander card LED - 16/16F LED Annunciator DRV - 50 LED driver RLY - 5 Relay expander card FCB - 1000Fiber interface bridge SPG - 1000 Serial/Parallel printer card MC - 1000 Multi-connector module 3005013 EOLR 3005012 EOLR Diode Refer to listee's Installation Instruction Manual for details.

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

RATING:	Primary Operating Supply: 120/240 VAC 2.5A Secondary Operating Supply 27.3 VDC 1.0 A
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model designation, rating and UL label.
APPROVAL:	Listed as fire alarm control units when use with separately listed electrically and functionally compatible initiating and indicating devices. Refer to listee's Installation Instruction Manual for details.
NOTES:	

03-12-2018 dcc

This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 05/09/2023

Listing Expires: 06/30/2024

Authorized By: **Victor Wong**, Program Coordinator
Fire Engineering & Investigations Division