



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7300-0328:0516
PARENT LISTING No.:	7300-0569:0127
CATEGORY:	7300 - FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES
LISTEE:	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Lakomiak, Neil 314-816-8679 Email: neill@pottersignal.com
DESIGN:	Model SLP-24 strobe lights. Units employ a strobe flash tube and electronic trigger circuit mounted on a printed wiring board with a clear lens. Models with suffix 'A', 'B', 'G', or 'R' employ an Amber, Blue, Green, or Red lens, respectively. Unit is intended for indoor use, or outdoor use when combined with Gentex enclosure Model GOE or Model GOELP (CSFM Listing No. 7300-0569:124) only. Unit is for private mode signaling use only. May be followed by -W (wall) and -W or -R (white or red), -P or -LP (plain or low profile). Refer to listee's data sheet for additional product description and operational considerations.
RATING:	Electrical:16 - 33 VDC Candela: 75cd
INSTALLATION:	In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, electrical ratings, and UL label.
APPROVAL:	Listed as strobes for use with separately listed compatible fire alarm control units. Not approved for hearing impaired applications.
NOTES:	

*Revision 05-01-
20 VWW





**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 07/26/2024

Listing Expires: 06/30/2025

Authorized By: **David Castillo** , Program Coordinator
Fire Engineering & Investigations Division