

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7165-0328:0517

Page 1 of 1

CATEGORY: 7165 -- FIRE ALARM CONTROL UNIT (COMMERCIAL)

LISTEE: Potter Electric Signal Co1609 Park 370 Place, Hazelwood, MO 63042 United States
Contact: Bill Witherspoon (314) 595-6731 Fax (314) 595-6999
Email: billw@pottersignal.com

DESIGN: PotterNet-Server-UL, and PotterNet-Client-UL Supervising Station Control Unit. Remote station (REC), Proprietary (REC) and Central Station (REC) services. Only one server is permitted per system and can send signals to a maximum of 15 clients. The server can also act as a client version as it employs both the client graphical user interface and software server. Client can monitor up to 1000 FACP's. Refer to listee's Installation Instruction Manual for details.

RATING: 120/240 VAC

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as a supervising station control unit for use with listee's separately listed compatible control units: IPA-4000, IPA-100, IPA-60 (CSFM No. 7165-0328:0500); AFC-1000, AFC-100, AFC-50, ARC-100 (CSFM No. 7165-0328:0509); PFC-4064 (CSFM No. 7165-0328:0511). Refer to listee's Installation Instruction Manual for details.

10-21-19 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2020**

Listing Expires **June 30, 2021**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**

Fire Engineering Division