

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7300-0328:0520 Page 1 of 1

**CATEGORY:** 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

**LISTEE:** Potter Electric Signal Co1609 Park 370 Place, Hazelwood, MO 63042 United States  
Contact: Brad Serangeli (314) 595-6731 Fax (314) 595-6999  
Email: brads@pottersignal.com

**DESIGN:** Model NCE-1000 Ethernet Network Card and Model NCF-1000 Fiber Network Card. Units provide networking capability of compatible fire alarm panels using ethernet or fiber optic cable. Intended for indoor dry locations.

Refer to listee's printed data sheet for additional detailed product description and operational considerations.

**RATING:** 24 Vdc Nominal

**INSTALLATION:** In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, rating, installation environment (indoor dry), and UL label.

**APPROVAL:** Listed as control unit accessories for use with listee's separately listed compatible fire alarm control panels.

Compatible Fire Alarm Control Panels:  
Models IPA-60, IPA-100, and IPA-4000 (CSFM Listing No. 7165-0328:0500)  
Models AFC-50, AFC-100, AFC-1000, and ARC-100 (CSFM Listing No. 7165-0328:0509)  
Model PFC-4064 (CSFM Listing No. 7165-0328:0511)

Refer to listee's Installation Instruction Manual for details.

11-24-20 VWW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **December 14, 2020**

Listing Expires **June 30, 2021**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**  
*Fire Engineering Division*