

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-0328:0522 Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: Potter Electric Signal Co1609 Park 370 Place, Hazelwood, MO 63042 United States
Contact: Brad Serangeli (314) 595-6900 Fax (314) 595-6999
Email: brads@pottersignal.com

DESIGN: Model CSS Coil Supervisory Switch. Product electronically monitors the position of a coil (opens, shorts, and ground continuity) on a solenoid for a preaction/deluge system. Intended for indoor dry locations only.

Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Input: 24 VDC Regulated
Output: 1 A at 30 VDC Resistive

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 13, NFPA 72, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating, and UL label.

APPROVAL: Listed as control unit accessories for use with listee's separately listed compatible fire alarm control units. Authority having jurisdiction should be consulted prior to installation. Refer to listee's Installation Instruction Manual for details.

3-18-21 VWW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2021**

Listing Expires **June 30, 2022**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**
Fire Engineering Division