



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	7300-0328:0523
<b>CATEGORY:</b>	7300 - FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES
<b>LISTEE:</b>	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Lakomiak, Neil 314-816-8679 Email: neill@pottersignal.com
<b>DESIGN:</b>	<p>Model SignalLink Wireless Mesh System, consists of Model WTX-M Transmitter, Model WR Wireless Repeater, and Model WRX-R Wireless Receiver. The Wireless Mesh System is a primary battery system that can be used to create a wireless network. The transmitter connects to a dry contact type initiating device and the receiver provides a dry contact output to the FACP. Each receiver can only communicate with a single dedicated transmitter. Suitable for outdoor and damp environment.</p> <p>Refer to listee's data sheet for additional detailed product description and operational considerations.</p>
<b>RATING:</b>	<p>Model WTX-M: Input Voltage: 3.0VDC (Two Energizer Ultimate Lithium L91 Batteries, Size AA, 1.5V)</p> <p>Model WR: Input Voltage: 24VDC wired or 3.6VDC (One Xeno Energy XL-205F Battery, Size D, 3.6V)</p> <p>Model WRX-R: Input Voltage: 24VDC</p>
<b>INSTALLATION:</b>	In accordance with listee's printed installation instructions, NFPA 13, NFPA 72, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
<b>MARKING:</b>	Listee's name, model number, rating, and UL label.



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

**APPROVAL:**

Listed as control unit accessories for use with separately listed compatible fire alarm control units. Authority having jurisdiction should be consulted prior to installation. Refer to listee's Installation Instruction Manual for details.

**NOTES:**

7-19-21 VWW



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 05/27/2025**

**Listing Expires: 06/30/2026**

Authorized By: **Michael Huang**, Program Coordinator  
Fire Engineering & Investigations Division