



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7300-0328:0539
CATEGORY:	7300 - FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES
LISTEE:	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Lakomiak, Neil 13148661542 Email: neill@pottersignal.com
DESIGN:	<p>Models PAD300-4DB and PAD300-6DB Detector Base. Models PAD300-4DB-I and PAD300-6DB-I Isolator Detector Base. All models employ the same basic construction, and differ only by terminals for circuit isolation. Model PAD300-4DB is a 4 in. (10.2 cm) base with 2 terminal contacts. Model PAD300-6DB is a 6 in. (15.2 cm) base with 2 terminal contacts. Model PAD300-4DB-I is a 4 in. (10.2 cm) base with 3 terminal contacts used for isolation purposes. Model PAD300-6DB-I is a 6 in. (15.2 cm) base with 3 terminal contacts used for isolation purposes.</p> <p>Refer to listee's printed data sheet for additional detailed product description and operational considerations.</p>
RATING:	Electrical ratings can vary depending on compatible detector models used.
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, electrical rating, and UL label.



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

APPROVAL:	<p>Listed as bases for use with listee's separately listed detector heads. Refer to listee's Installation Instruction Manual for details. Models complies with the applicable requirements in UL 268, 7th Edition, UL 521, 7th Edition, and UL 2075, 2nd Edition.</p> <p>Compatible Detectors:</p> <p>Models PAD300-CD and PAD300-CD-I (CSFM Listing No. 5278-0328:0537)</p> <p>Models PAD300-HD and PAD300-HD-I (CSFM Listing No. 7270-0328:0538)</p> <p>Model PAD300-DD (CSFM Listing No. 3242-0328:0540)</p> <p>Models PAD300-PD, PAD300-PD-I, PAD300-PHD, and PAD300-PHD-I (CSFM Listing No. 7272-0328:0541)</p> <p>Models PAD300-PCD, PAD300-PCD-I, PAD300-PHD, and PAD300-PHD-I (CSFM Listing No. 7275-0328:0542)</p>
NOTES:	

1-27-23 VWW



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 05/03/2024

Listing Expires: 06/30/2025

Authorized By: **David Castillo** , Program Coordinator
Fire Engineering & Investigations Division