



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7300-0328:0544
CATEGORY:	7300 - FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES
LISTEE:	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Lakomiak, Neil 13148661542 Email: neill@pottersignal.com
DESIGN:	<p>Model PAD300-SB Sounder Base and Model PAD300-LFSB Low Frequency Sounder Base. Products do not consume extra addresses on the loop but are assigned a sub-address from the attached detector. They are independent devices that may be programmed as a single station, zone, or all call sounders. They can be programmed to produce a variety of sound patterns required by different commercial and residential applications. The available patterns include Constant, ANSI Temp 3, March Code, Double Time, and ANSI Temp 4. Once activated, the sounder will follow the input from the power source to reproduce the programmed pattern and deactivate accordingly.</p> <p>Refer to listee's printed data sheet for additional detailed product description and operational considerations.</p>
RATING:	16.0 – 33.0 VDC
INSTALLATION:	In accordance with the listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, electrical rating, and UL label.



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

APPROVAL:	<p>Listed as bases for use with listee’s separately listed detector heads. Refer to listee’s Installation Instruction Manual for details. Model complies with the applicable requirements in UL 268, 7th Edition, UL 464, 10th Edition, and UL 521, 7th Edition.</p> <p>Compatible Detectors:</p> <p>Models PAD300-PD, PAD300-PD-I, PAD300-PHD, PAD300-PHD-I (CSFM No. 7272-0328:0541)</p> <p>Models PAD300-HD, PAD300-HD-I (CSFM No. 7270-0328:0538)</p> <p>Compatible Fire Alarm Control Panels:</p> <p>Models IPA-60, IPA-100, IPA-4000 (CSFM No. 7165-0328:0500)</p> <p>Models AFC-50, AFC-100, AFC-1000, ARC-100 (CSFM No. 7165-0328:0509)</p>
NOTES:	

1-27-23 DAL



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee’s data sheet, installation instructions and/or other suitable information sources.

Date Issued: 05/03/2024

Listing Expires: 06/30/2025

Authorized By: **David Castillo** , Program Coordinator
Fire Engineering & Investigations Division