

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL FIRE ENGINEERING & INVESTIGATIONS DIVISION BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No.:	7320-0328:0549
PARENT LISTING No.:	7320-0785:0505
CATEGORY:	7320 - SPEAKERS
LISTEE:	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Lakomiak, Neil (314) 595-6748 Email: neill@pottersignal.com
DESIGN:	Models PE-SPKx-y [a] and PE-SPKxC-y [a] Speakers, mounted on a wall or ceiling. Models PE-SPSTx-y [a] and PE-SPSTx-yA [a] Speaker/Strobes, mounted on a wall. Models PE-SPSTxC-y [a] and PE-SPSTxC-yA [a] Speaker/Strobes, mounted on a ceiling. Strobes are synchronous or non-synchronous. Amber lens are intended for Private Mode Emergency Use only. All models are intended for indoor use only and may be followed by a suffix representing lettering and color as noted below: [a] - Where x represents product color, y represents lettering. Refer to listee's data sheet for additional detailed product description and operational considerations.
RATING:	Speaker Voltage: 25 Vrms; 1/8 W, 1/4 W, 1/2 W, 1 W, or 2 W 70.7 Vrms; 1/8 W, 1/4 W, 1/2 W, 1 W, or 5 W Strobe Voltage: 16-33 VDC, 16-33 Vfwr Candela Rating for models PE-SPSTx-y and PE-SPSTx-yA: 15, 30, 75, 110, 135, or 185 cd Candela Rating for models PE-SPSTxC-y and PE-SPSTxC-yA: 15, 30, 75, 95, 150, or 177 cd
INSTALLATION:	In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.



CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL FIRE ENGINEERING & INVESTIGATIONS DIVISION BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

MARKING:	Listee's name, model number, rating, and UL label.
APPROVAL:	Listed as speakers and speaker/strobes for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.
NOTES:	

02-05-24 MH



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test resultsand/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 02/08/2024 Listing Expires: 06/30/2024

Authorized By: **David Castillo**, Program Coordinator Fire Engineering & Investigations Division