



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	7770-0328:0550
<b>CATEGORY:</b>	7770 - VALVES/SWITCHES
<b>LISTEE:</b>	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Lakomiak, Neil 314-816-8679 Email: neill@pottersignal.com
<b>DESIGN:</b>	VSR-AT Series Auto-test Waterflow Alarm Switches comes in sizes for 2, 2-1/2, 3, 3-1/2, 4, 5, 6, and 8 in. pipe. Unit is a vane type waterflow alarm switch with an electronic retard and auto test feature. May be mounted on a horizontal or vertical pipe.  Refer to listee's printed data sheet for detailed product descriptions and operational considerations.
<b>RATING:</b>	For All Sizes:  Electrical Rating: 2.5A, 125/250VAC; 2.5A, 30 VDC  Service Pressure Rating: 450 PSI  Enclosure Rating: NEMA 4
<b>INSTALLATION:</b>	In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
<b>MARKING:</b>	Listee's name, model number, rating, and UL label.
<b>APPROVAL:</b>	Listed as waterflow indicator for use with fire sprinkler systems. Must be inspected in accordance with NFPA 25, 2013 California Edition. Refer to listee's Installation Instruction Manual for details.
<b>NOTES:</b>	

04-24-24 MH



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

**Date Issued: 03/26/2026**

**Listing Expires: 06/30/2027**

Authorized By: **Michael Huang**, Program Coordinator  
Fire Engineering & Investigations Division