CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No.:	7300-0328:0552
CATEGORY:	7300 - FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES
LISTEE:	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Lakomiak, Neil 13145956704 Email: neill@pottersignal.com
DESIGN:	Model PC-RA remote indicator is designed for use with listee's separately listed compatible fire alarm system devices and panels. It is designed for indoor, wall mount use on a standard single gang electrical backbox. Product has one (1) LED to indicate the device status and is for supplemental notification only and is not intended as the primary evacuation signal appliance. The product shall be circuited to the detector and the LED status is synchronized with the connected conventional detector. Refer to listee's data sheet for detailed product description and operational considerations.
RATING:	12 or 24 VDC
INSTALLATION:	In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, electrical rating and UL label.
APPROVAL:	Listed as remote indicators for use with the following separately listed compatible detectors, and listee's separately listed control units. Refer to listee's Installation Instruction Manual for details. Compatible Detectors: PC-2P, PC-2PN (CSFM Listing No. 7272-0328:0553), PC-2PH (CSFM Listing No. 7272-0328:0554), and PC-2H (CSFM Listing No. 7270-0328:0555)
NOTES:	

02-25-25 MH

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

Date Issued: 03/07/2025

Listing Expires: 06/30/2025

Authorized By: **Michael Huang**, Program Coordinator
Fire Engineering & Investigations Division