# CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
# OFFICE OF THE STATE FIRE MARSHAL
# FIRE ENGINEERING & INVESTIGATIONS DIVISION
# BUILDING MATERIALS LISTING PROGRAM

## LISTING SERVICE

| | |
|---|---|
| **LISTING No.:** | 7272-0328:0553 |
| **CATEGORY:** | 7272 - SMOKE DETECTOR-SYSTEM TYPE-PHOTOELECTRIC |
| **LISTEE:** | Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042<br>Contact: Lakomiak, Neil 314-816-8679<br>Email: neill@pottersignal.com |
| **DESIGN:** | Models PC-2P and PC-2PN photoelectric smoke detector heads. For use with listee's separately listed compatible detector bases and listee's separately listed fire alarm control panels. Models are for indoor, wall, or ceiling mounted in operating temperatures between 32°F - 115°F, and open air velocities from 0 to 300 ft/min. Detectors can be sold separately or together with the separately listed 6" mounting base, PC-6DB. The PC-2P6B is the model including the PC-2P detector and the PC-6DB base, while the PC-2PN6B is the model including the PC-2PN detector and the PC-6DB base.<br><br>Refer to listee's printed data sheet for additional detailed product description and operational considerations. |
| **RATING:** | 12 or 24 VDC |
| **INSTALLATION:** | In accordance with the listee's printed installation instructions, applicable codes and ordinances, NFPA 72, and in a manner acceptable to the authority having jurisdiction. |
| **MARKING:** | Listee's name, model number, electrical rating, and UL label. |
| **APPROVAL:** | Listed as photoelectric smoke detector heads for use with listee's separately listed compatible detector bases and listee's separately listed fire alarm control panels. Models are for indoor, wall, or ceiling mounted in operating temperatures between 32°F - 115°F, and open air velocities from 0 to 300 ft/min. Models comply with the applicable requirements in UL 268, 7th edition. Refer to listee's Installation Instruction Manual for details.<br><br>Compatible Remote Indicator: PC-RA (CSFM Listing No. 7300-0328:0552)<br><br>Compatible Detectors Bases: PC-4DB, and PC-6DB (CSFM Listing No. 7300-0328:0556) |
| **NOTES:** | |

02-25-25 MH

# CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
# OFFICE OF THE STATE FIRE MARSHAL
# FIRE ENGINEERING & INVESTIGATIONS DIVISION
# BUILDING MATERIALS LISTING PROGRAM

## LISTING SERVICE

This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 03/27/2026**

**Listing Expires: 06/30/2027**

Authorized By: **Michael Huang**, Program Coordinator
Fire Engineering & Investigations Division