



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE
PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7320-0328:0558
PARENT LISTING No.:	7320-0785:0167
CATEGORY:	7320 - SPEAKERS
LISTEE:	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Lakomiak, Neil 314-816-8679 Email: neill@pottersignal.com
DESIGN:	Outdoor series notification devices Speaker models: PE-4XSPK and PE-3RSPK speakers; PE-WPSPK speaker subassembly. Speaker/strobe models: PE-4XSPST and PE-3RSPST speaker/strobes; PE-WPSPST speaker/strobe subassembly. Speaker/strobe with amber lens (Emergency Warning): PE-4XSPSTA and PE-3RSPSTA speaker/strobes; PE-WPSPSTA speaker/strobe subassembly. Speaker/strobe with blue, green, red lens (Private Mode): PE-4XSPSTB, PE-4XSPSTG, PE-4XSPSTR, PE-3RSPSTB, PE-3RSPSTG, and PE-3RSPSTR speaker/strobes; PE-WPSPSTB, PE-WPSPSTG, and PE-WPSPSTR speaker/strobe subassemblies. All model numbers may include a suffix representing product color (R or W for red or white) and may include a suffix representing lettering. Refer to listee's data sheet for detailed product description and operational considerations.



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE
PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

RATING:	Speaker Voltage: 25 Vrms; 1/8, 1/4, 1/2, 1 or 2 W 70.7 Vrms; 1/8, 1/4, 1/2, 1, 2, 4 or 8 W Strobe Voltage: 24 VDC (16-33 VDC), 24 VFWR (16-33 VFWR) Strobe Light Output Candela: Clear (white) - 185, 150, 110, 75, 30, 15 cd Amber - 177, 150, 95, 75, 30, 15 cd Blue - 150, 135, 95, 75, 30, 15 cd Green - 125, 115, 75, 60, 30, 15 cd Red - 80, 75, 50, 40, 20, 10 cd
INSTALLATION:	In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, electrical/candela rating, and UL label.
APPROVAL:	Only models PE-4XSPST, PE-3RSPST, and PE-WPSPST are suitable for the deaf and hard of hearing when used with separately listed electrically compatible fire alarm control units. Other models are not suitable for the deaf and hard of hearing applications when used with a separately listed compatible fire alarm control unit. All models are intended for indoor/outdoor use and wall or ceiling installation. All Speaker/Strobes are intended for synchronous or non-synchronous operation. Refer to listee's Installation Instruction Manual for details. Models PE-4XSPK, PE-3RSPK, and PE-WPSPK comply with the applicable requirements in UL 1480, 7th Edition. Models PE-4XSPST, PE-3RSPST, and PE-WPSPST comply with the applicable requirements in UL 1480, 7th Edition, UL 1638, 6th Edition and UL 1971, 3rd Edition. Models PE-4XSPSTA/B/G/R, PE-3RSPSTA/B/G/R, and PE-WPSPSTA/B/G/R comply with the applicable requirements in UL 1480, 7th Edition and UL 1638, 6th Edition.
NOTES:	



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE
PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

08-26-25 MH



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 04/02/2026

Listing Expires: 06/30/2027

Authorized By: **Michael Huang** , Program Coordinator
Fire Engineering & Investigations Division