



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE
PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7300-0328:0560
PARENT LISTING No.:	7300-0785:0166
CATEGORY:	7300 - FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES
LISTEE:	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Lakomiak, Neil 314-816-8679 Email: neill@pottersignal.com
DESIGN:	Potter Outdoor series notification devices Horn models: PE-4XHN and PE-3RHN horns; PE-4XMT and PE-3RMT multitone horns; PE-WPHN horn subassembly; PE-WPMT multitone horn subassembly. Strobe models: PE-4XST and PE-3RST strobes; PE-WPST strobe subassembly. Strobe models with amber lens (Emergency Warning): PE-4XSTA and PE-3RSTA strobes, and PE-WPSTA strobe subassembly. Strobe models with blue, green, red lens (Private Mode): PE-4XSTB, PE-4XSTG, PE-4XSTR, PE-3RSTB, PE-3RSTG, and PE-3RSTR strobes; PE-WPSTB, PE-WPSTG, and PE-WPSTR strobe subassemblies. Horn/strobe models: PE-4XHS and PE-3RHS horn/strobes; PE-4XMTST and PE-3RMTST multitone horn/strobes; PE-WPHS horn/strobe subassembly; PE-WPMTST multitone horn/strobe subassembly. Horn/strobe models with amber lens (Emergency Warning): PE-4XHSA and PE-3RHSA horn/strobes; PE-4XMTSTA and PE-3RMTSTA multitone horn/strobes; PE-WPHSA horn/strobe subassembly; PE-WPMTSTA multitone horn/strobe subassembly. Horn/strobe models with blue, green, and red lens (Private Mode): PE-4XMTSTB, PE-4XMTSTG, PE-4XMTSTR, PE-3RMTSTB, PE-3RMTSTG, and PE-3RMTSTR multitone horn/strobes; PE-WPMTSTB, PE-WPMTSTG, and PE-WPMTSTR multitone horn/strobe subassemblies. All model numbers may include a suffix representing product color (R or W for red or white) and may include a suffix representing lettering. Models PE-WPHN, PE-WPMT, PE-WPST/A/B/G/R, PE-WPHS/A, and PE-WPMTST/A/B/G/R are subassemblies intended for use with Listed models EL4XBB or EL3RMP (CSFM Listing No. 7300-0785:0168). All models may be installed with Listed replacement grille accessory (CSFM Listing No. 7300-0785:0168). Refer to listee's data sheet for detailed product description and operational considerations.



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE
PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

RATING:	Models PE-WPHS, PE-WPHSA, PE-WPST, PE-WPSTA, PE-WPSTB, PE-WPSTG, PE-WPSTR, PE-WPMTST, PE-WPMTSTA, PE-WPMTSTB, PE-WPMTSTG, and PE-WPMTSTR - 24 VDC/FWR (16-33 VDC/FWR) Models PE-WPHN and PE-WPMT - 24 VDC/FWR (16-33 VDC/FWR), 12 VDC/FWR (8-17.5 VDC/FWR) Strobe Light Output Candela: Clear (white) - 185, 150, 110, 75, 30, 15 cd Amber - 177, 150, 95, 75, 30, 15 cd Blue - 150, 135, 95, 75, 30, 15 cd Green - 125, 115, 75, 60, 30, 15 cd Red - 80, 75, 50, 40, 20, 10 cd
INSTALLATION:	In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, electrical/candela rating, and UL label.



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE
PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

APPROVAL:	Only models PE-4XST, PE-3RST, PE-WPST, PE-4XHS, PE-3RHS, PE-WPHS, PE-4XMTST, PE-3RMTST, and PE-WPMTST are suitable for the deaf and hard of hearing when used with separately listed electrically compatible fire alarm control units. Other models are not suitable for the deaf and hard of hearing applications when used with a separately listed compatible fire alarm control unit. All models are intended for indoor/outdoor use and wall or ceiling installation. All strobes, horn/strobes and multitone horn/strobes are intended for synchronous or non-synchronous operation. Refer to listee's Installation Instruction Manual for details. Models PE-WPHN, PE-WPMT, PE-WPST/A/B/G/R, PE-WPHS/A, and PE-WPMTST/A/B/G/R are subassemblies intended for use with Listed models EL4XBB or EL3RMP (CSFM Listing No. 7300-0785:0168). All models may be installed with Listed replacement grille accessory (CSFM Listing No. 7300-0785:0168). Models PE-4XHN, PE-3RHN, PE-4XMT, PE-3RMT, PE-WPHN, and PE-WPMT comply with UL 464, 11th edition. Models PE-4XST, PE-3RST, and PE-WPST comply with UL 1638, 6th edition and UL 1971, 3rd edition. Models PE-4XSTA/B/G/R, PE-3RSTA/B/G/R, and PE-WPSTA/B/G/R comply with UL 1638, 6th edition. Models PE-4XHS, PE-3RHS, PE-4XMTST, PE-3RMTST, PE-WPHS, and PE-WPMTST comply with UL 464, 11th edition, UL 1638, 6th edition and UL 1971, 3rd edition. Models PE-4XHSA, PE-3RHSA, PE-4XMTSTA/B/G/R, PE-3RMTSTA/B/G/R, PE-WPHSA, and PE-WPMTSTA/B/G/R comply with UL 464, 11th edition and UL 1638, 6th edition. Models PE-WPHS, PE-WPHSA, and PE-WPHN horn can generate a distinctive 3-Pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72.
NOTES:	

02-12-26 MH



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 04/02/2026

Listing Expires: 06/30/2027



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE
PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

Authorized By: **Michael Huang** , Program Coordinator
Fire Engineering & Investigations Division