



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7165-0328:0562
CATEGORY:	7165 - FIRE ALARM CONTROL UNIT (COMMERCIAL)
LISTEE:	Potter Electric Signal Co 1609 Park 370 Place, Hazelwood, MO, 63042 Contact: Lakomiak, Neil 314-816-8679 Email: neill@pottersignal.com



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

DESIGN:

Models EVAX-5070, EVAX-10070, EVAX-X70 Conventional Voice Evacuation Panels. Models are suitable for local, EVAC emergency signaling, and mass notification in-building services. Subassembly Model CIM-16 Input module provides 16 inputs which are activated via normally open dry contacts.

Refer to listee's data sheet for additional detailed product description and operational considerations.

Minimum system configurations:

EVAX-5070

EVAX-5070: Internal 50W, Single Channel Amplifier

RM-1000ECS: Remote Microphone

PSN-1000(E): Intelligent Notification Power Expander

EVAX-10070

EVAX-5070: Internal 50W, Single Channel Amplifier

SCA-5070INT: 50W Integrated Amplifier

RM-1000ECS: Remote Microphone

FFT-10000L, FFT- 1000R: Fire Fighter Telephone System

PSN-1000(E): Intelligent Notification Power Expander

EVAX-X70

EVAX-X70: Expandable 50W, Single Channel Amplifier

SCA-2525, SCA-2570, SCA-5025, SCA-5070, SCA-5070INT, SCA-10070: Single Channel Amplifiers

DCA-5025, DCA-10025: Dual Channel Amplifier, 25V

70V-1000: 70V Voltage Booster DCA Amplifiers

RM-1000ECS: Remote Microphone

FFT-10000L, FFT-1000R: Fire Fighter Telephone System

PSN-1000(E): Intelligent Notification Power Expander

CIM-16: Contact Input Module

SB-24: Switch Board (24 Programmable Switches)



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

RATING:	Models EVAX-5070, EVAX-10070, EVAX-X70: Primary Operating Supply Input: 120/240Vac, 50/60Hz, 5/3A Secondary Operating Supply Voltage: 24 VDC, 55Ah Model CIM-16: 24 VDC
INSTALLATION:	In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, electrical rating, and UL label.
APPROVAL:	Listed as fire alarm control units for use with separately listed compatible initiating and indicating devices. Models comply with the applicable requirements in UL 864, 10th Edition. Refer to listee's Installation Instruction Manual for details.
NOTES:	For Fire Alarm Verification Feature (delay of fire alarm signal), the maximum Retard/Reset/Restart period shall not exceed 30 seconds. Alarm Verification shall not be implemented on initiation-device circuits that have the option of releasing an extinguishing agent or water unless these circuits release independently of the Alarm Verification feature.

08-28-26 MH



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 09/01/2026

Listing Expires: 06/30/2027

Authorized By: **Michael Huang**, Program Coordinator
Fire Engineering & Investigations Division