

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7320-1517:0110

**CATEGORY:** 7320 -- SPEAKERS

**LISTEE:** COMMERCIAL PRODUCTS GROUP (CPG)1609 Park 370 Place, Hazelwood, MO 63031  
Contact: Brad Serangeli (314) 595-6731 Fax (309) 762-8215  
Email: brads@pottersignal.com

**DESIGN:** Model SPHP speaker. Refer to listee's data sheet for detailed product description and operational considerations. Additional information may also be found in UL Fire Protection Directory.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction. Suitable for indoor and outdoor use.

**MARKING:** Listee's name, model number, electrical ratings and UL label.

**APPROVAL:** Listed as a speaker for use with separately listed compatible fire alarm control units and visual signal appliances.

If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

07-12-10 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**  
*Fire Engineering Division*