

The following is a list of compatible releasing devices for release capable Potter panels:

(All 24 VDC Devices, only one device per circuit unless stated otherwise)

- PFC-6500R
- IPA Series (IPA-60, IPA-100, IPA-4000)
- ARC-100
- Private labeled panels JFS-IP60, JFS-IP127, JFS-IP4000
- AFC Series (AFC-50, AFC-100, AFC-1000)

Underwriters Laboratories

AFC Series (AFC-50, AFC-100, AFC-1000)

- Parker – 73212BN4TNLVN0C322C2
- Parker – 73218BN4UNLVN0C111C2
- Parker – 7321GBN99NLVN0C322C2
- Victaulic – 753-E Series
- Viking – 11591, 11601, 11602, 13843 and 13844

PFC-6500R, IPA Series (IPA-60, IPA-100, IPA-4000), ARC-100, Private labeled panels JFS-IP60, JFS-IP127, JFS-IP-4000

- FM200 Electric Valve Actuator – 18481
- Minimax MX1230 and MX200 with Minimax 885738, 887667 and 889323 actuators
- Minimax - OXEO PR LCP with actuators 914027 and 925585 (EPU-1)
- Viking - VSN200, VSN1230, VSH200, and VSH1230 with 885738, 887667 and 889323 actuators
- Viking - Viking OXEO PR with actuators 914027 and 925585 (MZ-1)
- Nohmi - Koatsu R85M14, R85M10-N
- Parker – 73212BN4TNLVN0C322C2
- Parker – 73218BN4UNLVN0C111C2
- Parker – 7321GBN99NLVN0C322C2
- TLX - PA0036, PA0337
- Victaulic – 753-E Series
- Viking – 11591, 11601, 11602, 13843 and 13844
- Fireaway – Stat-X Models 30E, 60E, 100E, 250E, 500E, 1000E, 1500E, and 2500E
Aero-K Models G30, G60, G100, G250, G500, G1000, G1500, and G2500
(Maximum of 10 per circuit)
- Kidde - WK-890181-000
- Kidde - WK-897494-000

Factory Mutual (IPA Series/ARC-100 only)

Group 4